



GOVERNMENT OF TELANGANA
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT
NO OBJECTION CERTIFICATE



From
The Director General
State Disaster Response and Fire Services,
Telangana, Hyderabad.

To,
Jagadishwar rao,
JRS SCHOOL
SY.NO.725.KORREMULA,
NARAPALLY,
NEAR UPPAL DEPOT,
MEDCHAL-MALKAJIGIRI DISTRICT,

Re. No.339480002020 Dated:14/09/2020

Sir,

Sub:

TELANGANA STATE DISASTER RESPONSE & FIRE SERVICE DEPARTMENT –

Issue of No Objection Certificate for Occupancy to the Non Multi storeyed Building of **JRS SCHOOL ,JRS SCHOOL SY.NO.725.KORREMULA,NARAPALLY,NEAR UPPAL DEPOT,MEDCHAL-MALKAJIGIRI DISTRICT/- Korremul/Ghatkesar/Medchal**, Hyderabad – Regarding.



Ref:

1. Acknowledgement No339480002020 dt.14/09/2020
2. This Office Provisional NOC Ack No./RC No.201320002019 dt.06/06/2019
3. Inspection Committee Report, Ack No. 339480002020, dt. 14/09/2020

1. The Multi Storeyed Building Inspection committee, vide reference cited (3) have inspected the Non Multi Storeyed Building of **JRS SCHOOL ,JRS SCHOOL SY.NO.725.KORREMULA,NARAPALLY,NEAR UPPAL DEPOT,MEDCHAL-MALKAJIGIRI DISTRICT/- Korremul/Ghatkesar/Medchal** and submitted the following report.

2. The builder was issued Provisional No Objection certificate vide reference cited (2) for construction of Non Multi Storeyed Building **Ground, 3 Floors**, with for Occupancy (). Now the builder has constructed Non Multi Storeyed Building with **Ground, 3 Floors**, with a height of **14.64** Meters for **EDUCATIONAL B-1 Schools up to senior secondary level** Occupancy () and requested for No Objection Certificate for Occupancy.

3. Open Spaces : The builder provided the following open spaces all around the building.

Sl.No	side	Open space Required as per Provisional No Objection Certificate	Open space Provided
1	North	6.00	6.00
2	South	6.00	6.00
3	East	7.50	6.00
4	West	6.00	6.00
5	Front Direction East		

4. Means of Access :

Sl No	Gate Width As per NBC 2016	Required	Provided
1	Entry gate width	6.00	6
2	Exit Gate Width	6.00	6
3	Entry Gate Head Clearance	4.50	4.5
4	Exit Gate Head Clearance	4.50	4.50

5. Travel Distance

Sl No.	Item / Description	Required (Not More than in Mtrs.)	Provided
1	Farthest point (Most Remote Point) With in a storey or a mezzanine floor to the door to an Exit.	30.00	28.00
2	The Dead end of the corridor length in exit access. (6 mtrs for Educational, Institutional and Assembly, 15mtrs for other Occupancies)	6.00	5.00